


Chariton Valley Biomass Project

Summary of Fly Ash Sampling and Test Results from December 2003 Interim Test Burn at Ottumwa Generation Station

> *Presented to: Iowa Department of Transportation June 29, 2005*






### **Overall Project Objectives**

- Create a new business opportunity in Southern Iowa—using switchgrass as fuel at OGS
- 25,000 to 50,000 acres for supplying biomass fuel
- Environmental improvements
  - Air emissions
    - Reduced sulfur and greenhouse gas emissions
  - Water and soil quality
- New source of income from marginal farm lands in Southern Iowa












### **Proposed Commercial Construction**



# Project Status Update Completed Interim Test Burn (Dec. 2003) – 12.5 ton/hr target Completed emissions analysis for Interim Test Burn Submitted final report to IDNR Submitted permit applications Received permits for commercial operation at 25 ton/hr Design of facility for Long Term Test Burn completed Construction under way for Long Term Test Burn facility Seeking IDOT approval for use of fly ash from Long Term Test Long Term Test Burn—Winter/Spring 2006























Switchgrass Blow Lines Transporting Ground Switchgrass into Boiler House (left) and Boiler (right).





# **Required Test Parameters**



- Accomplished
- Sample and analyze daily samples of coal & SWG
  - Accomplished
- Collect more than enough fly ash for ISU & IDOT testing
  - Accomplished



- Co-fired 1,673 bales of SWG (781 tons)
  - Average Weight of 931 lbs.
  - Average Moisture 12.9%
- Gathered nearly 300 samples for lab analysis
  - Raw Coal Samples
  - SWG Samples ( baled, debaled, ground )
  - Ash Samples (Bottom ash, Fly ash, Economizer)
  - Liquids ( bottom ash )
- Collected 2,760 lbs. of Fly Ash for Analysis & Testing
  - 160 lbs. from auto sampler ( 5 gallon buckets )
  - 2,600 lbs. from bulk samples ( 55 gallon drums )



# **Test Burn Statistics (cont.)**

Daily Switchgrass Feed Rates


- Average = 8.9 tph (1.9% of heat input to boiler)
- Range: 5.6 to 10.6 tph (1.1% to 2.2% of heat input to boiler)
- Maximum *Instantaneous* Feed Rate: 11.6 tph

### **Average Feed Rates & F-Factors**


Date	Average SWG Flow Rate (tons/hr)	Average Heat Input from SWG <sup>1</sup>	Average Coal Fuel Factor	Average Switchgrass Fuel Factor	Average Combined Fuel Factor	Soda Ash Feed Rate (Ib per ton of Coal)
12/1/2003	10.6	2.1%	1,876	1,929	1,876	2.50 to 3.00 <sup>2</sup>
12/2/2003	8.6	1.8%	1,873	1,946	1,873	3.00
12/3/2003	8.4	1.6%	1,867	1,919	1,867	3.00
12/4/2003	5.9	1.1%	1,862	1,905	1,862	3.00
12/5/2003	10.1	2.1%	1,865	1,959	1,865	3.00
12/6/2003	n/a	n/a	1,863	n/a	1,863	3.00
12/7/2003	n/a	n/a	1,856	n/a	1,856	3.00
12/8/2003	8.4	1.9%	1,857	1,939	1,857	3.00
12/9/2003	n/a	n/a	1,851	n/a	1,851	3.00
12/10/2003	9.5	2.0%	1,869	1,926	1,869	3.00
12/11/2003	9.6	2.2%	1,890	1,968	1,896	3.00 to 3.25 <sup>2</sup>
12/12/2003	n/a	n/a	1,870	n/a	1,870	3.25
Total	8.9	1.9%	1,866	1,936	1,867	




# **Completed Lab Testing**




• Fly ash properties and performance (ISU)


























# **Bulk Fly Ash Sample Collection**



